

WELL LOG AND DRILLING REPORT

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus 12, Ohio

ORIGINAL
(56)

No 312839

County Carroll Township Lee Section of Township

Owner O DELL RECTOR Address Harlem Springs

Location of property near Harlem Springs

CONSTRUCTION DETAILS

Casing diameter 6 1/4 Length of casing 142
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST

Pumping Rate 1 G.P.M. Duration of test 9 hrs.
Drawdown ft. Date Sept 12
Static level-depth to water 50 ft.
Quality (clear, cloudy, taste, odor)
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From 0 Feet	To Ft.
Clay	30	
sand	10	40
Shale	7	47
Clay	15	62
Shale	18	88
lime water	8	88
Slate	4	92
sand water	10	102
white clay	10	107
Shale Brown	10	118
sand	10	123
Clay	10	130
Coal	10	132
Clay	10	142
Clay	10	150
Shale	10	160
Shale	10	170
sand	10	177
Shale	10	197
Clay	10	190
Shale	10	

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

Shale 7 ft to 197 ft
sand 3 ft to 200
Shale 9 ft to 200 ft
sand 2 to 210
Shale 10 to 220
sand 2 to 232
Shale 9 to 232
sand 2 to 240
Shale 9 to 240
Shale block
sand and shale 20 ft to 261

W.

E.

Route 43
Harlem Springs
well

S.

See reverse side for instructions

Drilling Firm Clark Drilling Co

Date Sept 12 1964

Address Toronto B.D. 10th

Signed C Clark

(84)