

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

PLEASE USE PENCIL
OR TYPEWRITER
DO NOT USE INK.

DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus 12, Ohio

19
No 324104

County Fayette Township Concord Section of Township

Owner Maurice Sollars Address

Location of property Sollars Road off Route 72

CONSTRUCTION DETAILS

Casing diameter 5 $\frac{5}{8}$ Length of casing 32
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion Dec. 23, 1964

BAILING OR PUMPING TEST


Pumping Rate 30 G.P.M. Duration of test 1 hrs.
Drawdown 3 ft. Date Dec. 23, 1964
Static level-depth to water 12 ft.
Quality (clear, cloudy, taste, odor) cloudy
Pump installed by

WELL LOG

Formations Sandstone, shale, limestone, gravel and clay	From	To
	0 Feet	Ft.
old well	0	15'
sand	15'	25'
blue clay	25'	32'
limestone	32'	70' W.

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



1036
32
1004

See reverse side for instructions

Drilling Firm Putledge Well Drilling Date Dec. 23, 1964

Address R R # 4, Wilmington Signed Rodney L. Putledge

LOCATED

19-9