

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

No 325211

County Montgomery Township Perry Section of Township #27
Owner Max Perkins Address 1020 N. JOHNSVILLE Rd.
Location of property N. E. corner N. Johnsville rd. & Old Dayton rd.

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 95'
Type of screen — Length of screen —
Type of pump —
Capacity of pump —
Depth of pump setting —
Date of completion 8-27-65 Drilling

BAILING OR PUMPING TEST

Pumping Rate 10 G.P.M. Duration of test 2 hrs.
Drawdown 40 ft. Date 9-8-65
Static level-depth to water 20 ft.
Quality (clear cloudy, taste, odor) no odor.
Pump installed by —

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay</u>	<u>0 Feet</u>	<u>31 Ft.</u>
<u>Sand & gravel</u>	<u>31</u>	<u>33</u>
<u>Sand & gravel</u>	<u>33</u>	<u>58</u>
<u>Sand & gravel</u>	<u>58</u>	<u>60</u>
<u>Dark Clay</u>	<u>60</u>	<u>63</u>
<u>Gravel & Clay</u>	<u>63</u>	<u>72</u>
<u>Clay</u>	<u>72</u>	<u>95'</u>
<u>Gravel at 95 ft</u>		
<u>1689</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N. Johnsville rd.
some water
some water
some water
W.
E.
well.
old Dayton rd
S.

See reverse side for instructions

Drilling Firm M. J. Spencer Date Sept. 8, 1965
Address 3404 Susanna Ave Signed Marion J. Spencer
Dayton, O. Phone 275-0865

*If additional space is needed to complete well log, use next consecutive numbered form.