WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

PLEASE USE PENCIL OR TYPEWRITER

DO NOT USE INK.

№ 326200

County Franklin Township Washington Section of Township South - East

Owner Duane Plorhett Address 5539 Tuttle Rd

Location of property Betan Hayden Run - Ringe Rd

CONSTRUCTION DETAILS

Casing diameter 4 in Length of casing 6

Type of screen Brass Length of screen

Type of pump

Capacity of pump 8 GPH.

Depth of pump setting 40

Date of completion 1-16-69

BAILING OR PUMPING TEST

Pumping Rate 15 G.P.M. Duration of test 2 hrs.

Drawdown 7 ft. Date 1-16-

Static level-depth to water 13 ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by Everett Stefflebow

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay	0 Feet	22 Ft.
Sand Clay	22	33
Clay	33	54
Sand & Gravel	54	67

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Everett Stefflebow Date 1-16-69

Address 9445 Plain City Signed Everett Stefflebow

*If additional space is needed to complete well log, use next consecutive numbered form.

F319