

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

State of Ohio
DEPARTMENT OF NATURAL RESOURCES

No 329782

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

DO NOT USE INK.

County WYANDOT Township SALEM Section of Township _____

Owner PAUL BOES Address UPPER SANDUSKY R.D.

Location of property ON U.S. 304

CONSTRUCTION DETAILS

Casing diameter 4 1/2" Length of casing 59'
Type of screen — Length of screen —
Type of pump JET
Capacity of pump 8 GPM
Depth of pump setting 45'
Date of completion 1/3/66

BAILING OR PUMPING TEST


Pumping Rate _____ G.P.M. Duration of test _____ hrs.
Drawdown 15 ft. Date _____
Static level-depth to water 25 ft.
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by _____

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>YELLOW CLAY</u>	<u>0 Feet</u>	<u>15 Ft.</u>
<u>STONES</u>	<u>15</u>	<u>17</u>
<u>BLUE CLAY</u>	<u>17</u>	<u>35</u>
<u>SAND + CLAY</u>	<u>35</u>	<u>40</u>
<u>STONES</u>	<u>40</u>	<u>42</u>
<u>SAND + GRAVEL</u>	<u>42</u>	<u>45</u>
<u>BLUE CLAY</u>	<u>45</u>	<u>50</u>
<u>SAND + GRAVEL</u>	<u>50</u>	<u>55</u>
<u>LIMESTONE</u>	<u>55</u>	<u>72</u>
<u>WATER AT 68'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm Donald Cole
Address WHARTON, O.

Date 1/20/66
Signed Donald Cole

*If additional space is needed to complete well log, use next consecutive numbered form.

(19)