WELL-LOG AND DRILLING REPORT

ORIGINAL

19d

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

PLEASE USE PENCIL OR TYPEWRITER

DO NOT USE INK.

№ 336484

County Paulding Township Carryall Section of Township 2

Owner Glen Hissong Address R2

Location of property 1 mi. north Antwerp, Then east on River Rd approx 2 miles

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 58'

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST

Pumping Rate 10 G.P.M. Duration of test 2 hrs.

Drawdown ft. Date October 1972

Static level-depth to water 31 ft.

Quality (clear, cloudy, taste, odor) clear

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Yellow clay	0 Feet	24 Ft.
Blue clay	24	44
Sand	44	58
Sand rock	58	64

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm F B Derck Date October 31, 1972

Address Antwerp Ohio Signed Francis Derck (R.D)

*If additional space is needed to complete well log, use next consecutive numbered form.

23