190

WELL LOG AND DRILLING REPORT

PLEASE USE PENCIL OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

№ 337293

County Mahoning Township Goshen Section of Township 15

Owner Jim Isley Address 192 W 10th St Salem, O.

Location of property Off Diagonal Rd 450 ft North west of (165)

CONSTRUCTION DETAILS

Casing diameter 6 1/4" Length of casing 64'

Type of screen Length of screen

Type of pump Deep well

Capacity of pump

Depth of pump setting 80'

Date of completion 4-4-67

BAILING OR PUMPING TEST

Pumping Rate 10 G.P.M. Duration of test 1/2 hrs.

Drawdown 20 ft. Date 4-4-67

Static level-depth to water 40 ft.

Quality (clear, cloudy, taste, odor)

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay	0 Feet	10 Ft.
Sand & Clay	10	30
Clay	30	64
Shale	64	100
Sandrock	100	120
Water	115	

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



ELEV. OF ROCK: 1179

See reverse side for instructions

Drilling Firm Kendall Ingram Date 4-4-67

Address 857 Jennings Ave Salem O. Signed Kendall Ingram

*If additional space is needed to complete well log, use next consecutive numbered form.

190