

ORIGINAL

Nº 341808

**Division of Water
1562 W. First Avenue
Columbus, Ohio 43212**

County Warren Township Hamilton Section of Township _____
Owner Gordon H. Wyles Address 6800 Styber Rd. ^{Engineering Co.}
Location of property 1 mi W 3-22 6800 Styber Rd mainerville

CONSTRUCTION DETAILS

Casing diameter 6.00 Length of casing 82
Type of screen none Length of screen none
Type of pump deep well
Capacity of pump 8
Depth of pump setting 105
Date of completion 8-3-66

BAILING OR PUMPING TEST

Pumping Rate 1.5 G.P.M. Duration of test 2 hrs.
Drawdown 10 ft. Date 8-3-66
Static level-depth to water 62 ft.
Quality (clear, cloudy, taste, odor) Clean
Pump installed by Birchwell Drilling

WELL LOG*

[illegible]

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

maineville. O

1.5 MI -> Pt

WELL

W. KING MILL O

2 MI

E.

S.

See reverse side for instructions

Drilling Firm *W. E. Smith*
Address *412 Crawford St*
Midd. Ct.

Date 8-23-66
Signed William Birch

*If additional space is needed to complete well log, use next consecutive numbered form.

11