

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

No 342717

County STARK Township LAKE Section of Township _____

Owner JOSEPH A. SNYDER Address 4336 PORTAGE N.W. N. CANTON

Location of property 9944 CLEVELAND AVE. GREENTOWN, O.

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 51-9

Type of screen _____ Length of screen _____

Type of pump _____

Capacity of pump _____

Depth of pump setting _____

Date of completion _____

BAILING OR PUMPING TEST

Pumping Rate 18 G.P.M. Duration of test 1 hrs.

Drawdown 47 ft. Date 4-19-66

Static level-depth to water 30 ft.

Quality (clear, cloudy, taste, odor) _____

CLEAR


Pump installed by _____

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>SAND & GRAVEL</u>	<u>0 Feet</u>	<u>36 Ft.</u>
<u>SHALE</u>	<u>36</u>	<u>38</u>
<u>LIMESTONE</u>	<u>38</u>	<u>39-6</u>
<u>COAL</u>	<u>39-6</u>	<u>42</u>
<u>SHALE</u>	<u>42</u>	<u>50</u>
<u>SAND ROCK</u>	<u>50</u>	<u>53</u>
<u>SHALE</u>	<u>53</u>	<u>93</u>
<u>SAND ROCK</u>	<u>93</u>	<u>115</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm KENNETH WATZ & SONS

Date 4-19-66

Address 715 ORRVILLE N.W.
MASSILLON

Signed Kenneth Watz

*If additional space is needed to complete well log, use next consecutive numbered form.