

ORIGINAL

**Division of Water
1562 W. First Avenue
Columbus, Ohio 43212**

County LUCAS Township HARDING Section of Township _____

Owner ERNA WEISWEDER Address RT 295 - SWANTON, OHIO

Location of property RT 295 + ANGOLA RDC

CONSTRUCTION DETAILS

Casing diameter 5 Length of casing 46'

Type of screen.....Length of screen.

Type of pump 3 HP SUB

Capacity of pump.....12 GPM

Depth of pump setting.....100'

Date of completion. JUNE 25, 77

BAILING OR PUMPING TEST

Pumping Rate 3 G.P.M. Duration of test 4 hrs.

Drawdown 28 ft. Date JUNE 25, 77

Static level-depth to water 22 ft.

Quality (clear, cloudy, taste, odor) CLEAR SWEET
SOME SALT

Pump installed by AL. T. PLADY

WELL LOG*

[illegible]

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

5987-295

W.

E.

ANGOLA
RD

S.

See reverse side for instructions

Drilling Firm NORMAN T. PLADY

Date JUNE 25, 77

Address 1-1390-3 SWANTON, O.
43552

Signed Norman Tisdley

*If additional space is needed to complete well log, use next consecutive numbered forms.

13