

ORIGINAL

№ 346126

DO NOT USE INK.

Location of property 2 mi. North of Fredricktown on Rt 546

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST
Casing diameter <u>4 1/4</u> Length of casing <u>72</u>	Pumping Rate <u>20</u> G.P.M. Duration of test <u>1/2</u> hrs.
Type of screen _____ Length of screen _____	Drawdown <u>9</u> ft. Date <u>Oct 17, 66</u>
Type of pump <u>Deep well</u>	Static level-depth to water <u>46</u> ft.
Capacity of pump <u>8 gpm</u>	Quality (clear, cloudy, taste, odor) <u>Clear</u>
Depth of pump setting <u>60'</u>	
Date of completion <u>Oct 17, 66</u>	Pump installed by <u>Deep well Drilling</u>

[illegible]

Signed Donald J. Deal

26