

ORIGINAL

Nº 348946

DO NOT USE INK.

Location of property 11001 BROWER ROAD

BAILING OR PUMPING TEST

Pumping Rate. 454 G.P.M. Duration of test 24 hrs.
Drawdown. ? ft. Date 12/14/72
Static level-depth to water. 54'-4" ft.
Quality (clear, cloudy, taste, odor) CLEAR -
ODORLESS - TASTELESS
Pump installed by DIEHL PUMP

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W. STATION RD

BROWER ROAD

100 YD

300 YD

WELL

OHIO RIVER

S.

E.

NORTH BEND OHIO

See reverse side for instructions

Signed L F Brewer

*If additional space is needed to complete well log, use next consecutive numbered form.