

ORIGINAL

Nº 349063

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

County Portage Township Franklin Section of Township East-Central
Owner Lucien Ernes Address Willard Rd. Kent, O.
Location of property Willard Rd. - 1/2 mile south of State Rt 5

CONSTRUCTION DETAILS

Casing diameter 4 Length of casing 82
Type of screen drop Length of screen 3 ft
Type of pump jet
Capacity of pump 7 GPM
Depth of pump setting 20 ft.
Date of completion Oct 20-66

BAILING OR PUMPING TEST

Pumping Rate 18 G.P.M. Duration of test 2 hrs.
Drawdown 10 ft. Date Oct 24-66
Static level-depth to water 35 ft ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Driller

WELL LOG*

[illegible]

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W.

E.

S.

See reverse side for instructions

Drilling Firm

Address BOK 1565 Hwy, O.

Date

Signed

516
LOCATED

*If additional space is needed to complete well log, use next consecutive numbered form.