

III
ORIGINAL
23
Nº 353783
3rd floor Right
free they
across Rd
JK

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

353783
3rd from Right
free they
across, Rd

County Scioto Township Vernon Section of Township South
Owner Hennith Knapp Address Franklin Furnace Ohio
Location of property 2 MI. South on Poplar Fork Rd.

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST
Casing diameter <u>6"</u> Length of casing <u>16' 6"</u>	Pumping Rate <u>6</u> G.P.M. Duration of test <u>4</u> hrs.
Type of screen _____ Length of screen _____	Drawdown <u>30'</u> ft. Date <u>3-11-69</u>
Type of pump _____	Static level-depth to water <u>16' 6"</u> ft.
Capacity of pump _____	Quality (clear, cloudy, taste, odor) _____
Depth of pump setting _____	_____
Date of completion <u>3-17-69</u>	Pump installed by <u>M N O P P</u>

WELL LOG*			SKETCH SHOWING LOCATION	
Formations Sandstone, shale, limestone, gravel and clay	From	To	Locate in reference to numbered State Highways, St. Intersections, County roads, etc.	
Dirt	0 Feet	13 Ft.	N.	
Shale	13'	25'		
Rock	25	42' 6"		
Water			W.	E.
AT				
25'				
			S.	See reverse side for instructions

Drilling Firm H. Hughes.
Address Box 2 POTS. O.

Date 3-17-69
Signed Hargis Hughes

*If additional space is needed to complete well log, use next consecutive numbered form.