

ORIGINAL

180 ✓

Nº 354895

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

County Franklin Township Washington Section of Township _____

Owner Dwight Yeager Address 5542 Riverfront

Location of property Same

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 190'

Type of screen 1 Length of screen 1

Type of pump Submersible

Capacity of pump 129 P.m

Depth of pump setting.....100

Date of completion. July - 1969

BAILING OR PUMPING TEST

Pumping Rate 12 G.P.M. Duration of test 5 hrs.

Drawdown 0 ft. Date July-1967

Static level-depth to water 60 ft.

Quality (clear, cloudy, taste, odor).....

clear-

Pump installed by Lehman Drilling

WELL LOG*

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

0 Feet

30 Ft.

Clay

Limestone

Set 190' 4"

Plastic liner

Bass Island

at 160'

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

المسألة

W.

E.

S.

See reverse side for instructions

Drilling Firm Lehman Drilling

Address 5780 Franchard St
Westerville

Date Sept 21, 1969

Signed James H. Brown

*If additional space is needed to complete well log, use next consecutive numbered form.

A56