

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

No 355174

County LUCAS Township SYLVANIA Section of Township 9
Owner PAUL A KOEPEL Address 5046 KING ROAD (EXTENSION)
Location of property NO. 0 ON KING ROAD FROM BRINT RD 3/10 MILE

CONSTRUCTION DETAILS

Casing diameter 4 1/4 Length of casing 38
Type of screen NONE Length of screen -
Type of pump 1/2 H. SUB P. WITH SS ADP.
Capacity of pump 15 G.P.M.
Depth of pump setting 61
Date of completion 10-15-76


BAILING OR PUMPING TEST

Pumping Rate 17 G.P.M. Duration of test 2 hrs.
Drawdown 9 ft. Date 10-15-76
Static level-depth to water 24 ft.
Quality (clear, cloudy, taste, odor) _____
Pump installed by OWNER (CONTRACTOR)

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>SAND</u>	<u>0 Feet</u>	<u>12 Ft.</u>
<u>CLAY</u>	<u>12</u>	<u>26</u>
<u>CLAY-GRAVEL</u>	<u>26</u>	<u>35</u>
<u>SAND-GRAVEL</u>	<u>35</u>	<u>38</u>
<u>SAND STONE</u>	<u>38</u>	<u>48</u>
<u>LIME STONE</u>	<u>48</u>	<u>53</u>
<u>SAND STONE</u>	<u>53</u>	<u>62</u>
<u>LIME STONE</u>	<u>62</u>	<u>66</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

See reverse side for instructions

Drilling Firm Orin Smith
Address 3147 PLAINVIEW DR
TOLEDO OHIO 43615Date NOV 15-76
Signed Orin Smith

*If additional space is needed to complete well log, use next consecutive numbered form.

PH. (419) 841 3880

(87)