WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

PLEASE USE PENCIL OR TYPEWRITER
DO NOT USE INK.

№ 356903

County GREENE Township BEAVERCREEK Section of Township 2

Owner ROLAND KANTNER Address 5402 ARDONNA DRIVE

Location of property WOODHAVEN PLAT - LOT # 306 - ON ROSENDALE DR (170)
1 MILE SOUTH of ROUTE 35

LOT # 306

CONSTRUCTION DETAILS

Casing diameter 6" OD Length of casing 56

Type of screen — Length of screen —

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST

Pumping Rate 15 G.P.M. Duration of test 2 hrs.

Drawdown 4 ft. Date

Static level-depth to water 36 ft.

Quality (clear, cloudy, taste, odor)

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
TOPSOIL	0 Feet	3 Ft.
BROWN CLAY	3	17
DIRTY GRAVEL	17	40
BLUE CLAY	40	50
WATER GRAVEL	50	56

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm NORMAN DRILLING CO. Date June, 1967

Address 448 PANDORA DRIVE DAYTON OHIO 45431 Signed Norman Drilling Co.

LOCATED (54)

*If additional space is needed to complete well log, use next consecutive numbered form.