

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

State of Ohio
DEPARTMENT OF NATURAL RESOURCES

No 359153

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

County Ross Township Buckskin Section of Township _____

Owner Village of Greenfield Address Greenfield, Ohio

Location of property At Test Hole 4 location

CONSTRUCTION DETAILS

Casing diameter 12" Length of casing 30'
Type of screen 100 slot Length of screen 9'
Type of pump Screen 30-37' exposed
Capacity of pump _____
Depth of pump setting _____
Date of completion May 31, 1966

BAILING OR PUMPING TEST

Pumping Rate 150 G.P.M. Duration of test 24 hrs.
Drawdown 7.8 ft. Date 6-6-66
Static level-depth to water 1.0 ft.
Quality (clear, cloudy, taste, odor) _____
Pump installed by _____

12" Pumping Well WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Black Top Soil</u>	<u>0 Feet</u>	<u>5 Ft.</u>
<u>Yellow sandy clay</u>	<u>5</u>	<u>11</u>
<u>Yellow sandy clay and gravel</u>	<u>11</u>	<u>13</u>
<u>Boulders and med. to</u>	<u>13</u>	<u>15</u>
<u>coarse gravel</u>		
<u>Boulders and medium to</u>	<u>16</u>	<u>18 1/2</u>
<u>coarse sand</u>		
<u>Med. to large gravel and</u>	<u>18 1/2</u>	<u>19</u>
<u>coarse sand</u>		
<u>Yellow sandy clay and gravel</u>	<u>19</u>	<u>26</u>
<u>Gray clay and gravel</u>	<u>26</u>	<u>30</u>
<u>Pea to med. gravel and</u>	<u>30</u>	<u>33</u>
<u>med. to large gravel, silty</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.
12" Pumping Well at Test
Hole 4 site.

See Log No. 335790 for
Sketch map.
W. South E.
St.

S.
See reverse side for instructions

Drilling Firm Herman Drilling Inc.
Address 3912 Mountview Rd., Columbus, O.

Date 10-66
Signed Everett G. Herman

*If additional space is needed to complete well log, use next consecutive numbered form.

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

State of Ohio
DEPARTMENT OF NATURAL RESOURCES

Nº 359154

Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

County Ross Township Buckskin Section of Township _____

Owner Village of Greenfield Address Greenfield, Ohio

Location of property At Test Hole 4 site

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

Casing diameter 12" 100 slot Length of casing 30'

Type of screen Red Brass Length of screen 9'

Type of pump Screen 30-37' exposed

Capacity of pump _____

Depth of pump setting _____

Date of completion May 31, 1966

Pumping Rate 150 G.P.M. Duration of test 24 hrs.

Drawdown 7.8 ft. Date 6-6-66

Static level-depth to water 7.0 ft.

Quality (clear, cloudy, taste, odor) _____

Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

0 Feet

Ft.

Pea to med. gravel, large
gravel and boulders

33

37

Gray clay and gravel

37

38

Pea to med. gravel, large

38

39

to coarse gravel, clay,

large flat rocks

Bedrock

39

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

12" Pumping Well (cont'd.)

South St.

W.

E.

S.

See reverse side for instructions

Drilling Firm Hamon Drilling Inc.

Date Oct. 1, 1966

Address 3912 Mountview Rd., Columbus, O.

Signed Everett B. Hamon

*If additional space is needed to complete well log, use next consecutive numbered form.