# WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

PLEASE USE PENCIL OR TYPEWRITER

DO NOT USE INK.

№ 365228

County Fairfield Township Pleasant Section of Township 2

Owner Mr. Roland Peters Address Foster St., Pleasantville, Ohio

Location of property On Carroll-Eastern Rd. near Co. Rd. 60

## CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 137'

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

## BAILING OR PUMPING TEST

Pumping Rate 10 G.P.M. Duration of test 3½ hrs.

Drawdown 100 ft. Date July 1, 1969

Static level-depth to water 57 ft.

Quality (clear, cloudy, taste, odor)

Pump installed by

## WELL LOG*

| Formations Sandstone, shale, limestone, gravel and clay | From | To |
|---|---|---|
| Black clay | 0 Feet | 3 Ft. |
| Yellow sand/clay | 3 | 30 |
| Gray sand/clay | 30 | 50 |
| Gray sand, muck | 50 | 70 |
| Gray sand | 70 | 100 |
| Yellow sand | 100 | 115 |
| Black sand | 115 | 118 |
| Sand mixed w/gravel | 118 | 137 |
| 10 gal. per minute at 100 ft. | | |

## SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.




See reverse side for instructions

Drilling Firm Herbert Wagner & Son Date July 1, 1969

Address R.D. 2, Lancaster, Ohio Signed Herbert W. Wagner
Keith Wagner, Driller

*If additional space is needed to complete well log, use next consecutive numbered form.