

WELL LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL
OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

C21
Nº 368438

County CARROLL Township FOX Section of Township 10
Owner FELIX HICKS Address RT. 2 SALINEVILLE
Location of property 2 MILES SOUTH WEST SALINEVILLE

CONSTRUCTION DETAILS			BAILING OR PUMPING TEST	
Casing diameter <u>6"</u> Length of casing <u>20'-3"</u>			Pumping Rate <u>4</u> G.P.M. Duration of test <u>1</u> hrs.	
Type of screen..... Length of screen.....			Drawdown <u>38</u> ft. Date.....	
Type of pump.....			Static level-depth to water <u>42</u> ft.	
Capacity of pump.....			Quality (clear, cloudy, taste, odor) <u>CLEAR</u>	
Depth of pump setting.....			Pump installed by.....	
Date of completion <u>11/10/1973</u>				
WELL LOG*			SKETCH SHOWING LOCATION	
Formations Sandstone, shale, limestone, gravel and clay	From	To	Locate in reference to numbered State Highways, St. Intersections, County roads, etc.	
<u>DIRT</u>	<u>0</u> Feet	<u>1</u> Ft.	N. STATERT 39 S. E. <u>1/4 MILE</u> PRIVATE RD <u>1 MILE</u> COUNTY RD 21	
<u>BROWN SAND</u>	<u>1</u>	<u>33</u>		
<u>GRAY SAND</u>	<u>33</u>	<u>39</u>		
<u>BROWN SAND</u>	<u>39</u>	<u>50</u>		
<u>GRAY SAND</u>	<u>50</u>	<u>59</u>		
<u>BROWN SAND</u>	<u>59</u>	<u>80</u>		
<u>GRAY SAND</u>	<u>80</u>	<u>100</u>		
<u>BLACK SLATE</u>	<u>100</u>	<u>110</u>		
<u>GRAY SAND</u>	<u>110</u>	<u>120</u>	W. 77M See reverse side for instructions	
<u>WATER AT 54'</u>				

Drilling Firm NEELY DRILLING Date 11/26/1973
Address 5060 PICADOR RD SOUTH EAST Signed KENNETH NEELY

*If additional space is needed to complete well log, use next consecutive numbered form.

(98)