

ORIGINAL

Nº 370202

State of Ohio

Division of Water

1562 W. First Avenue

Columbus, Ohio 43212

County Ashtabula Township ~~Cherry Valley~~ Section of Township Northwest

Owner Louis Petrus Address P#2 Andover, Ohio

Location of property 1/2 mile on Creek Rd. from Mells Rd.

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 39'

Type of screen.....Length of screen.....

Type of pump.

Capacity of pump.

Depth of pump setting

Date of completion 4/29/68

BAILING OR PUMPING TEST

Pumping Rate 30 G.P.M. Duration of test 1/2 hrs.

Drawdown 20 ft. Date 4/29/68

Static level-depth to water 10 ft.

Quality (clear, cloudy, taste, odor) clear

Pump installed by None (Bailing Test)

WELL LOG*

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

Clay	0 Feet	15 Ft.
------	--------	--------

Blue Clay - gravel in it	15	35
--------------------------	----	----

Soft Shale	35	38
------------	----	----

Hard Shale	38	41
------------	----	----

Water at 40°

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

W. Mells Rd.

Creek Rd.

Well

Stanhope Kelloggsville Rd.

Ayers Rd.

LOCATED

N.

E.

See reverse side for instructions

Drilling Firm Carl W. Burns

Date 5/6/68

Address R#2 Tisch Rd. Jefferson,
Ohio

Signed Carl W Burns

*If additional space is needed to complete well log, use next consecutive numbered form.