WELL-LOG AND DRILLING REPORT

ORIGINAL

PLEASE USE PENCIL OR TYPEWRITER

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

№ 370799

County TRUMBULL Township NEWTON Section of Township

Owner DONALD ALLMAN Address RT. 1. NEWTON FALLS. O.

Location of property ON TOMLINSON RD. 4 mi. SOUTH OF NEWTON FALLS

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 32

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST

Pumping Rate 30 G.P.M. Duration of test 2 hrs.

Drawdown 10 ft. Date 1-14-69

Static level-depth to water ARTESIAN ft.

Quality (clear, cloudy, taste, odor) CLEAR

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
CLAY	0 Feet	30 Ft.
SANDSTONE	30	40

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



See reverse side for instructions

Drilling Firm BURROWS Date 3-4-69

Address RT. 1. MANTUA. O. Signed D. X. BURROWS

3 LOCATED

*If additional space is needed to complete well log, use next consecutive numbered form.