

ORIGINAL

Nº 370800

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

County TRUMBULL Township NEWTON Section of Township _____

Owner RAY FULMILLO Address _____

Location of property HALLACK + YOUNG Rd. 5 mi. South of Newton
Mass. 01

BAILING OR PUMPING TEST

Casing diameter 16' 0.0 Length of casing 36 Pumping Rate 30 G.P.M. Duration of test 2 hrs.

Type of screen _____ Length of screen _____ Drawdown 5 ft. Date 1.1.69

Type of pump..... Static level-depth to water, 25 ft.

Capacity of pump..... Quality (clear, cloudy, taste, odor) Clear

Depth of pump setting.....

Date of completion..... Pump installed by.....

Pump installed by.....

SKETCH SHOWING LOCATION

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

0 Feet

Ft.

CLAY
SANDSTONE

34.

104

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W.

E.

S.

See reverse side for instructions

Drilling Firm BURROWS

Date 3-4-69

Address RT. 1, MANTUA, O.

Signed D. X. Burrows

*If additional space is needed to complete well log, use next consecutive numbered form.