

**PLEASE USE PENCIL
OR TYPEWRITER**

DO NOT USE INK.

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
1562 W. First Avenue
Columbus, Ohio 43212

Nº 372783

County Polombiana Township St. Elizabeth Section of Township 5 & 24

Owner Lewis Lee Address RD #2500 Cecil Rd.

Location of property County Rd # 428 1 mile North Colton, OR

CONSTRUCTION DETAILS

Casing diameter 5-5/8 Length of casing 2772 Pumping Rate 15 G.P.M. Duration of test 1/2 hrs.

Type of screen 19 Length of screen _____ Drawdown 50 ft. Date 8/9/69

Type of pump Electric 1700 1/2 hp Unit 3 HLF4 Static level-depth to water 12' 8" 50' ft.

Capacity of pump 100 gal. min. Quality (clear, cloudy, taste, odor) _____

Depth of pump setting 108'

Date of completion 8/8/69 Pump installed by M. H. B. 205

BAILING OR PUMPING TEST

Pumping Rate 15 G.P.M. Duration of test 1/2 hrs.

Drawdown 50' ft. Date 8/7/69

Static level-depth to water 128' 50' ft.

Quality (clear, cloudy, taste, odor)_____

Pump installed by M. H. & B 705

WELL LOG*

Formations
Sandstone, shale, limestone,
gravel and clay

From

To

0 Feet

Ft.

45

128

Water at 98 ft

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

W.

S.

See reverse side for instructions

Drilling Firm Miller Bros Drilling Co Date 8/27/69

Address P.O. Box 51 River Rd. Signed W. J. Smith

*If additional space is needed to complete well log, use next consecutive numbered form.

LOCATED