

ORIGINAL

Nº 373700

**Division of Water
1562 W. First Avenue
Columbus, Ohio 43212**

Location of property 1798 St Rt 725 W.

BAILING OR PUMPING TEST

Casing diameter <u>6"</u>	Length of casing <u>42'</u>	Pumping Rate <u>20</u> G.P.M.	Duration of test <u>2</u> hrs.
Type of screen <u>P. C.</u>	Length of screen <u>5'</u>	Drawdown <u>8</u> ft.	Date _____
Type of pump _____		Static level-depth to water <u>23'</u>	ft. _____
Capacity of pump _____		Quality (clear, cloudy, taste, odor) <u>Clear</u>	_____
Depth of pump setting _____		Pump installed by _____	_____
Date of completion <u>Sept 10, 1972</u>			

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

[illegible]

W.

N.

X

E

~~St Rt 725 W.~~

S.

See reverse side for instructions

Date Sept 10, 1972

Signed Elmer Back.

*If additional space is needed to complete well log, use next consecutive numbered form.

7.