

ORIGINAL

**Division of Water
1562 W. First Avenue
Columbus, Ohio 43212**

County Lebanon Township Newman Section of Township 3-3

Owner Owner Kennedy Address Thousand Pk.

Location of property 1 Mile West of Jt. Rt. 13 on Loop Rd 10

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 74

Type of screen PERF Length of screen 3'0"

Type of pump DW. JET

Capacity of pump..... 9 GPM

Depth of pump setting.....

Date of completion. Jan 1, 1969

WELL LOG*

[illegible]

BAILING OR PUMPING TEST

Pumping Rate 20 G.P.M. Duration of test 2 hrs.

Drawdown 6 ft. Date Oct 30, 1968

Static level-depth to water. 38' ft.

Quality (clear, cloudy, taste, odor) clear

Pump installed by Glenn C. Coffey, Jr.

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

W.

E

S.

See reverse side for instructions

Drilling Firm **WATER WELL DRILLING**

Date Oct. 30 1948

Address NEWARK, OHIO

Signed Glenn E. Wells, Jr.

*If additional space is needed to complete well log, use next consecutive numbered form.