WE LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 379226

County Lorain Township Huntington Section of Township Tract-3

Owner George Williams Address R.D.-1-Wellington 44090

Location of property Stewart-Rd.-2½-mi.-West-of St.-Rt.-58

CONSTRUCTION DETAILS

Casing diameter 4¼ Length of casing 35'-8"

Type of screen — Length of screen —

Type of pump —

Capacity of pump —

Depth of pump setting —

Date of completion 10-21-72

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 10 G.P.M. Duration of test ½ hrs.

Drawdown 40 ft. Date 10-21-72

Static level-depth to water 18' ft.

Quality (clear, cloudy, taste, odor) ✓

Pump installed by —

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Brown Clay	0 Feet	18 Ft.
Blue Clay	18	29
Grey Shale	29	35'-8"
Sandstone	35'-8"	35'-11"
Shaley SS	35'-11"	60

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm N W Larsen Date 10-24-72

Address R.D.-2 Wellington Signed M. W. Larsen

*If additional space is needed to complete well log, use next consecutive numbered form.

24