

ORIGINAL

No. 379227

County Ashland Township Jackson Section of Township 15
Owner Wm. - Wright Address R.D. - 3 - West - Salem
Location of property N. W. - Corner - St. Rt. 42 - & Twp. Rd - 101 - ^{2 1/2 - mi. - S.W.} of - West - Salem

CONSTRUCTION DETAILS	BAILING OR <u>PUMPING TEST</u> (Specify one by circling)
Casing diameter <u>4 1/2 galv.</u> Length of casing <u>71' 8 3/4"</u>	Test Rate <u>25</u> G.P.M. Duration of test <u>1</u> hrs.
Type of screen <u>SS - 30</u> Length of screen <u>3'</u>	Drawdown <u>20</u> ft. Date <u>5-1-73</u>
Type of pump <u> </u>	Static level-depth to water <u>20'</u> ft.
Capacity of pump <u> </u>	Quality (clear, cloudy, taste, odor) <u>Clean</u>
Depth of pump setting <u> </u>	
Date of completion <u>5-3-73</u>	Pump installed by <u> </u>

[illegible]

Date 5-3-73
Signed M. W. Larsen

*If additional space is needed to complete well log, use next consecutive numbered form