

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

162 OK
No. 383682
(SUMMER CORRAGE)

County WASHINGTON Township WATERFORD Section of Township _____

Owner MR. PAUL SMITH Address 1526 RUSSELL DR. STREETSBORO OHIO

Location of property 4 MI. N. OF BEVERLY ON SR 60 POWER PLANT ON OPPOSITE SIDE RIVER

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (Specify one by circling)

Casing diameter 6 IN. O.D. Length of casing 53-0
Type of screen PERF. CASING Length of screen 20-0
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____


Test Rate 1 G.P.M. Duration of test 1/2 hrs.
Drawdown TOTAL ft. Date 7-14-72
Static level-depth to water 2-0 ft.
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>SURFACE CLAY</u>	0 Feet	4-0 Ft.
<u>SANDY SHALE</u>	4-0	15-0
<u>SHALE</u>	15-0	26-0
<u>RED SHALE</u>	26-0	29-0
<u>SHALE</u>	29-0	35-0
<u>SAND ROCK</u>	35-0	42-0
<u>SHALE</u>	42-0	53-0
<u>TOTAL DEPTH</u>	<u>53-0</u>	
<u>WATER AT 35-0</u>		

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm TETHILL DRILLING SERVICE
Address STOCKPORT O.R.#2 43787

Date 7-14-72
Signed RE Tethill

*If additional space is needed to complete well log, use next consecutive numbered form.