

WELL LOG AND DRILLING REPORT

DRILLER'S COPY

NO CARBON DATING
NECESSARY—
SELF-TRANSFERRING

DEPARTMENT OF NATURAL RESOURCES
Division of Oil and Gas
65 S. Front St., Rm. 315
Columbus, Ohio 43260 (614) 465-2646

388894

County Medina Township Liverpool Section of Township North

Owner Sewer District #5 Address Medina Co. Ohio

Location of property Corner of Boston Rd & S.H. 252 Valley City, O

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 85
Type of screen Length of screen
Type of pump
Capacity of pump
Depth of pump setting
Date of completion

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 50 G.P.M. Duration of test 5 hrs.
Drawdown 15 ft. Date 5/22/70
Static level-depth to water 6' ft.
Quality (clear, cloudy, taste, odor) clear
Pump installed by Boiler Test

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Br clay & gravel</u>	<u>0 Feet</u>	<u>12 Ft.</u>
<u>grey clay</u>	<u>12</u>	<u>22</u>
<u>Sand</u>	<u>22</u>	<u>28</u>
<u>grey clay</u>	<u>28</u>	<u>83</u>
<u>Berea Sandstone</u>	<u>83</u>	<u>85</u>
<u>Water at</u>	<u>85'</u>	

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm Mark Drilling
Address Valley City, O

Date 5/22/70
Signed Robert E. Mark

*If additional space is needed to complete well log, use next consecutive number form.

