

ORIGINAL

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 391021

Location of property Salisbury Rd - 1/10 mile West of Weckerly Rd.

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 10 G.P.M. Duration of test 1 hrs.

Drawdown 10 ft. Date 4-3-69

Static level-depth to water.....26.....ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by.

Date of completion.....4-3-69

SKETCH SHOWING LOCATION

To

**Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.**

N.

Salisbury Rd
1/4 mile
□ Well

W.

E

S.

Weckerly Rd.

Date 4-10-69

Signed Cliff H. Owens

*If additional space is needed to complete well log, use next consecutive numbered form.