

WE LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

2493 #16
No. 392877

County Clinton Township Chester Section of Township Central
Owner Wilber McCarren Address Wilmington RR
Location of property 2nd Farm on right out of KINGMAN ON BRIMSTONE Rd.

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 125'
Type of screen None Length of screen —
Type of pump 3/4 hp Peda Sub
Capacity of pump 96 PM
Depth of pump setting 115'
Date of completion 7-29-72

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 19 G.P.M. Duration of test 2 hrs.
Drawdown 10 ft. Date 7-25-72
Static level-depth to water 50 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Wickett Drilling

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Topsoil - clay</u>	<u>0 Feet</u>	<u>10 Ft.</u>
<u>clay - some sand</u>	<u>10'</u>	<u>80'</u>
<u>sand + gravel</u>	<u>80'</u>	<u>85'</u>
<u>clay + sand</u>	<u>85'</u>	<u>120'</u>
<u>sand + gravel</u>	<u>120'</u>	<u>125'</u>
<u>Water AT 125'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm Wickett Drilling
Address Harveysburg Ohio

Date 8-2-72
Signed Robert E. Wickett

*If additional space is needed to complete well log, use next consecutive numbered form.