WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 400610

County Clark Township Springfield Section of Township N.E. (12)

Owner Lucille Dill Address 3929 Old Columbus Rd

Location of property Columbus Rd. at Bird Rd. (Springfield) O. 45503

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 95'

Type of screen P.C. Length of screen 5'

Type of pump JET

Capacity of pump 6 G.P.M.

Depth of pump setting 85'

Date of completion Oct 9, 1972

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 20 G.P.M. Duration of test 2 hrs.

Drawdown 9 ft. Date Oct 6, 72

Static level-depth to water 59' ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Brown Clay	0 Feet	32 Ft.
Gray Clay	32	90
Sand + Gravel	90	93
Gray Clay	93	95

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Back Bros. Date Oct 9, 1972

Address Camden, Ohio Signed Elmer Back

*If additional space is needed to complete well log, use next consecutive numbered form.

51