

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 402135

County CUYAHOGA Township PARMA Section of Township _____
Owner M. J. WEST Address 3311 DENTZLER RD., PARMA, OHIO 44134
Location of property SAME

CONSTRUCTION DETAILS

~~18" to foot~~
Casing diameter 5 1/2" Length of casing 36' 6"
Type of screen 5 1/2" ^{DRIVE SHILL} Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion RIG UP - DEC. 4 & 5 TH 1971
Dec 28 - 71

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate EST. 5-16 G.P.M. Duration of test 2 hrs.
120 GAL. OVER NIGHT
Drawdown _____ ft. Date DEC. 28, 1971
Static level-depth to water 11 ft.
Quality (clear, cloudy, taste, odor) TASTE - GOOD
Pump installed by _____

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>YELLOW CLAY</u>	<u>0 Feet</u>	<u>3 Ft.</u>
<u>SANDY YELLOW CLAY</u>	<u>3</u>	<u>7</u>
<u>BROKEN SOAPSTONE AND</u>		
<u>FINE GRAVEL - ALL COLORS 1/4" TO</u>		
<u>1/4" SIZE - - - - -</u>	<u>7</u>	<u>9</u>
<u>SANDSTONE SHELLS</u>		
<u>2" TO 18" THICK - WITH</u>		
<u>10% GRAY SHALE - - -</u>	<u>9</u>	<u>31</u>
<u>GRAY SHALE - FAIRLY</u>		
<u>HARD - 1/3 SOAPSTONE</u>	<u>31</u>	<u>88</u>
<u>STONE - VERY DARK MEDIUM</u>		
<u>HARD - 1/4 FT.</u>	<u>88</u>	<u>102</u>
<u>LT. GRAY SHALE - MEDIUM</u>		
<u>HARD - - - - -</u>	<u>102</u>	<u>117</u>
<u>WATER IN SANDSTONE 88 TO 102'</u>		
<u>TOTAL DEPTH</u>	<u>- -</u>	<u>117 FT.</u>
<u>PIPE: 1ST JOINT 11' 3"</u>		
<u>SECOND JOINT 11'</u>		
<u>THIRD JOINT 10' 9"</u>		
<u>PLUS SET-IN JOINT 3' 6"</u>	<u>TOTAL PIPE</u>	<u>36' 6"</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm BALDWIN DRILLING CO.
Address 1721 COLUMBIA RD
VALLEY CITY, OHIO 44280

Date Dec 28, 1975
Signed PAUL R. BALDWIN

*If additional space is needed to complete well log, use next consecutive numbered form.