

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 408174

County Fairfield Township Violet Section of Township _____
Owner Larry Harshbarger Address _____
Location of property Saylor Rd. North of Stemen Rd. 500-Ft.

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST (Specify one by circling)
Casing diameter <u>5"</u> Length of casing <u>39'</u>	Test Rate <u>6-</u> G.P.M. Duration of test <u>3-</u> hrs.
Type of screen <u>0</u> Length of screen <u>0</u>	Drawdown _____ ft. Date <u>July - 71</u>
Type of pump <u>0</u>	Static level-depth to water <u>13-</u> ft.
Capacity of pump <u>0</u>	Quality (clear, cloudy, taste, odor) <u>clear-</u>
Depth of pump setting <u>0</u>	
Date of completion <u>August 71</u>	Pump installed by <u>0-</u>

WELL LOG*			SKETCH SHOWING LOCATION
Formations Sandstone, shale, limestone, gravel and clay	From	To	Locate in reference to numbered State Highways, St. Intersections, County roads, etc.
<u>Yel. Clay</u>	<u>0 Feet</u>	<u>5 Ft.</u>	N. W. Stemen Rd. E. S. Saylor Rd.
<u>Gray Clay</u>	<u>5</u>	<u>30</u>	
<u>Gray Hard Pan</u>	<u>30</u>	<u>39</u>	
<u>Gray Hard Shale (sh)</u>	<u>39</u>	<u>58</u>	
<u>Pipe Pulled-</u>			

Drilling Firm R.H. Goodwin Date July - 1971
Address 1455 Striebel Rd. Signed R.H. Goodwin

*If additional space is needed to complete well log, use next consecutive numbered form.

254
LOCATED
254