WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 408977

County MERCER Township HOPEWELL Section of Township

Owner Robert LEUGERS Address RR3 Rockford O 45882

Location of property third house on ETCHAR RD.

CONSTRUCTION DETAILS

Casing diameter 4ID Length of casing 68'

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 28 G.P.M. Duration of test hrs.

Drawdown 2' ft. Date 7 14 72

Static level-depth to water 8' ft.

Quality (clear, cloudy, taste, odor) CLEAR

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
clay	0 Feet	28½ Ft.
sand	28½	50'
LIMESTONE	50'	110'

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm John J. Fisher Date 7/14/72

Address RR1 Coldwater O. 45828 Signed Gary A. Fisher

*If additional space is needed to complete well log, use next consecutive numbered form.

1