WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 410906

County Ashland Township Jackson Section of Township 26

Owner Bill Hastings Address R.#1 West Salem O

Location of property ½ mile north of St. 604 on Co # 174

CONSTRUCTION DETAILS

Casing diameter 5½" OD Length of casing 33

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 25 G.P.M. Duration of test ½ hrs.

Drawdown none ft. Date 7/26/71

Static level-depth to water 55 ft.

Quality (clear, cloudy, taste, odor)

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Yellow clay	0 Feet	27 Ft.
Sand stone + shale	27'	90'
T.D. 90'		
Water at 35'-60'-75'		

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



1151
27
1124

Drilling Firm Glenn Hottel Date 8/6/71

Address R.#1 West Salem, O Signed Glenn Hottel

*If additional space is needed to complete well log, use next consecutive numbered form.

TR 53

LOCATED