

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 417630

County Miami Township Newberry Section of Township 16
Owner Mr. Luther Houston Address East Broadway Corrington, Ohio
Location of property 1 Mi N. - Corrington, O. - 1/4 Mi E. - State Rt 48 on Piquette Clayton Rd

CONSTRUCTION DETAILS

Casing diameter 6" OD Length of casing 82'
Type of screen None Length of screen —
Type of pump 1/2 H.P. Subm.
Capacity of pump 12 G.P.M.
Depth of pump setting 64 ft.
Date of completion Sept 16th 1973

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 20 G.P.M. Duration of test 2 hrs.
Drawdown 5 ft. Date Sept 16th 1973
Static level-depth to water 48 ft.
Quality (clear, cloudy, taste, odor) Clear
Pump installed by T. M. Willard

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay</u>	<u>0 Feet</u>	<u>14 Ft.</u>
<u>Clay Shale</u>	<u>14</u>	<u>65</u>
<u>Blue Clay</u>	<u>65</u>	<u>76</u>
<u>Clay & Gravel</u>	<u>76</u>	<u>80</u>
<u>Gravel</u>	<u>80</u>	<u>82</u>
<u>Water @</u>	<u>82 ft.</u>	
RECEIVED		
SEP 27 1973		
HEALTH DEPARTMENT TROY, OHIO		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm T. M. Willard
Address Rt 4 Houston, Ohio

Date Sept 20th 1973
Signed T. M. Willard

*If additional space is needed to complete well log, use next consecutive numbered form.