

22

No. 417632

County Wash. Township Newberry Section of Township 13
Owner Ms. Joe Whitcomb Address 9515 W. Greenville Falls Rd
Location of property 1 1/2 Mi. South of State Rt. 185 - On E. Side of State Rt. 185

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate. 30 G.P.M. Duration of test. 2 hrs.
Drawdown 5 ft. Date Nov 15 1974
Static level-depth to water 28 ft.
Quality (clear, cloudy, taste, odor) Clear

Pump installed by H. W. McQuay

SKETCH SHOWING LOCATION

**Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.**

Clay	0 Feet	58 Ft.
Limestone	58	85
Water @ 65' to		85'

A hand-drawn map of Section 13. The map is a square divided into four quadrants by a horizontal line (Clayton Falls Rd.) and a vertical line (Orange Turn Rd.). The top boundary is labeled 'N. 500 ft. - 1905'. The top-left corner shows a 'Bridge' over the 'Stillwater River'. The bottom boundary is labeled 'S.'. The left boundary is labeled 'W.' and the right boundary is labeled 'E.'. In the center, 'Sec 13' is written. A small square with an arrow points to 'Clayton Falls Rd.'. A circle with the word 'LOCATED' inside is in the bottom-right quadrant. Below it, '222' and 'Klinger Rd.' are written. On the left side, 'Orange Turn Rd.' is written vertically. A 'wall' is indicated on the left side near the center.

RECEIVED

JUN 03 1974

HEALTH DEPARTMENT
TROY, OHIO

Drilling Firm

Date

Dec 1st 1973