WEL' LOG AND DRILLING REP'RT

ORIGINAL

1974 # 542

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 417633

County Miami Township New Berlin Section of Township 13

Owner Mr. Robert Stolner Address R#7 Covington, Ohio

Location of property 1½ Mi. S. of St Rt. 185 on Range Line Rd. West Side

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 68'

Type of screen — Length of screen —

Type of pump Submersible

Capacity of pump 20 G.P.M.

Depth of pump setting 65'

Date of completion Apr. 20 — 1974

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 30 G.P.M. Duration of test 1 hrs.

Drawdown 10 ft. Date May 19th 1974

Static level-depth to water 32' ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by [illegible]

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay	0 Feet	64 Ft.
Lime Stone	64	101
Water @ 85 - 101 ft.		

RECEIVED
JUN 03 1974
HEALTH DEPARTMENT
TROY, OHIO

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm

Address R #7 Troy, Ohio

Date [illegible]

Signed May 29th 1974

*If additional space is needed to complete well log, use next consecutive numbered form.