

WELL LOG AND DRILLING REPORT

ORIGINAL

98

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 417634

County Miami Township New Berry Section of Township 3
Owner Mr. Dale Miller Address R#1 Bradford Ohio
Location of property 1/2 Mi. S. Versailles Piqua Rd on Fetter Rd East Side

CONSTRUCTION DETAILS

Casing diameter 6" O.D. Length of casing 76'
Type of screen Length of screen
Type of pump 1 H.P. Submersible
Capacity of pump 30 G.P.M.
Depth of pump setting 105'
Date of completion July 15 - 1974

BAILING OR PUMPING TEST (Specify one by circling)

Test Rate 30 G.P.M. Duration of test 2 hrs.
Drawdown 60 ft. Date July 15th 1974
Static level-depth to water 30 ft ft.
Quality (clear, cloudy, taste, odor) Clear

Pump installed by Th. M. Middlebrook

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Clay</u>	<u>0 Feet</u>	<u>18 Ft.</u>
<u>Clay & Sand</u>	<u>18</u>	<u>65</u>
<u>Sand</u>	<u>65</u>	<u>74</u>
<u>Lime Stone</u>	<u>74</u>	<u>115</u>

Water @ 80 to 115 ft
Depth of Well 115 ft.


RECEIVED

JUL 25 1974

HEALTH DEPARTMENT
TROY, OHIO

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm Th. M. Middlebrook
Address R#1 Houston, Ohio

Date July 24th 1974
Signed Th. M. Middlebrook

*If additional space is needed to complete well log, use next consecutive numbered form.

PETER S Rd