

108

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 419212

County MAHONING Township AUSTINTOWN Section of Township EAST OF CENTER

Owner WICKLIFFE CONCRETE Address 116 S. MERIDIAN

Location of property 120' WEST OF MERIDIAN RD.

CONSTRUCTION DETAILS

Casing diameter 6" O.D. Length of casing 20
Type of screen NONE Length of screen NONE
Type of pump DEEP WELL
Capacity of pump 20 GPM.
Depth of pump setting 105'
Date of completion JAN 6, 1971

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 50 G.P.M. Duration of test 1 hrs.
Drawdown 23' ft. Date JAN 6, 1971
Static level-depth to water 17' ft.
Quality (clear, cloudy, taste, odor) _____
Pump installed by J.C. EVANS Co.

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>GLACIAL DRIFT</u>	<u>0 Feet</u>	<u>14 Ft.</u>
<u>GREY SHALE</u>	<u>14</u>	<u>36</u>
<u>SANDY GREY SHALE</u>	<u>36</u>	<u>49</u>
<u>GREY SANDROCK</u>	<u>49</u>	<u>98</u>
<u>GREY SHALE</u>	<u>98</u>	<u>120'</u>
<u>WATER @ 30'</u>		
<u>2nd WATER @ 95'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm J.C. EVANS Co.

Date FEB. 20, 1972

Address 4442 SOUTHERN BLVD.

Signed _____

YOUNGSTOWN, OHIO

*If additional space is needed to complete well log, use next consecutive numbered form.

108