WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 420386

County Huron Township Norwalk Section of Township 6 East

Owner Mr. A. Fritz Address Laylin Road

Location of property Same as Log 420385

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 16 ft.

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 3 G.P.M. Duration of test 1/2 hrs.

Drawdown ft. Date

Static level-depth to water 10 ft.

Quality (clear, cloudy, taste, odor)

Cloudy

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Top Soil	0 Feet	2 Ft.
Brown Clay	2	6
Sand Stone	6	52
Gray Shale	52	54
Black Shale	54	70

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Ohlemacher Drilling Date Aug. 10. 1933

Address R.R. #1 South Norwalk Rd Norwalk Ohio Signed John J. Ohlemacher

*If additional space is needed to complete well log, use next consecutive numbered form.

117-d