WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 420387

County Hudson Township Norwalk Section of Township East

Owner Mr. A. Fritz Address Jaylin Road.

Location of property Same as 420386

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 10

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 3 G.P.M. Duration of test 12 hrs.

Drawdown ft. Date

Static level-depth to water 11 ft.

Quality (clear, cloudy, taste, odor) Cloud

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Top Soil	0 Feet	2 Ft.
Brown Clay	2	4
Sand Stone	4	40

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Schmacker Drilling Date Aug. 10, 1973

#1