WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

No. 421622

County Trumbull Township Hartland Section of Township

Owner Ed Burnfield Address 4-2-2 Bond St

Location of property 8674 Hunters Trail Gibson Allot Hunters Wood

CONSTRUCTION DETAILS

Casing diameter 5 5/8" Length of casing 75

Type of screen none Length of screen

Type of pump

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 17 G.P.M. Duration of test 1 hrs.

Drawdown 2 ft. Date 12-20-71

Static level-depth to water 100' ft.

Quality (clear, cloudy, taste, odor)

Pump installed by

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay	0 Feet	4 Ft.
Brown sand	4'	10'
Shale	10'	25
White sandrock	25	40
Shale	60	186

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Mills Drilling Date 12-20-71

Address 488 N Hayden St. Cortland Signed Robert Mills

*If additional space is needed to complete well log, use next consecutive numbered form.