WEL LOG AND DRILLING REPORT

ORIGINAL

25c

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

425132

County DARKE Township Greenville Section of Township 9

Owner DWIGHT ARNOLD Address RR3 Greenville, O 45331

Location of property Bishop Rd.

CONSTRUCTION DETAILS

Casing diameter 4½" Length of casing 86'

Type of screen NONE Length of screen

Type of pump Submersible

Capacity of pump

Depth of pump setting

Date of completion

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 50 G.P.M. Duration of test 1 hrs

Drawdown 0 ft. Date 6-15-72

Static level-depth to water 26 ft.

Quality (clear, cloudy, taste, odor) Clear No odor

Pump installed by owner

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
clay	0 Feet	35 Ft.
gravel	35	86

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm JAKE CAMPBELL (Now Baker) Date 7-30-72

Address RR1 Roseburg, O. Signed Jake Campbell

*If additional space is needed to complete well log, use next consecutive numbered form.

314