

WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

425412

County HURON Township FITCHVILLE Section of Township _____
Owner Ron Winkel Address Old State RD. NORWALK, O.
Location of property DE. RUSSEY RD 3 1/2 MILES NORTH OF FITCHVILLE OHIO

CONSTRUCTION DETAILS

Casing diameter 5 3/8" Length of casing 112
Type of screen NONE Length of screen NONE
Type of pump NONE
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST (Specify one by circling)


Test Rate 5 G.P.M. Duration of test 1 hrs
Drawdown 4 ft. Date NOVEMBER 9, 72
Static level-depth to water 13 ft.
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by NONE

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>CLAY</u>	<u>0 Feet</u>	<u>18 Ft.</u>
<u>SILT SAND</u>	<u>18</u>	<u>45</u>
<u>CLAY</u>	<u>45</u>	<u>109</u>
<u>SAND</u>	<u>109</u>	<u>112</u>
<u>RED SHALE</u>	<u>112</u>	<u>126</u>
<u>GRAY SHALE</u>	<u>126</u>	<u>170</u>
<u>WATER</u>	<u>109</u>	

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm C & H
Address PIERCE ST. GREENWICH OHIO

Date NOVEMBER 9, 1972
Signed B. G. Horn

*If additional space is needed to complete well log, use next consecutive numbered form.