WELL LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER NECESSARY— SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

429869

County Clark Township Pike Section of Township 33 N.W.

Owner Donald M. Meyer Address 11681 Troy Rd New Carlisle O. 45344

Location of property On 11681 Troy Rd W. of Rt 69. 2 miles

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 52-18

Type of screen _____ Length of screen _____

Type of pump 1/2 HP Ruby

Capacity of pump 450 G.P.H.

Depth of pump setting 60 Prc.

Date of completion Sept 7-1972

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate 40 G.P.M. Duration of test 2 hrs

Drawdown — ft. Date Sept 6-1972

Static level-depth to water 35 ft.

Quality (clear, cloudy, taste, odor) _____

Pump installed by Power & Snyder

WELL LOG*

Formations Sandstone, shale, limestone, gravel and clay	From	To
Clay & Sand	0 Feet	52 Ft.
Limestone	52	18.
Best Strata of Good Water Left Strata is Schale		

SKETCH SHOWING LOCATION

Locate in reference to numbered State Highways, St. Intersections, County roads, etc.



Drilling Firm Power & Son. Date Sept 2-1972

Address 5763 W. Nat Pk. Sp. Fld O. Signed Edward N. Power

*If additional space is needed to complete well log, use next consecutive numbered form.

45