

ORIGINAL

15,

435062

Columbus, Ohio 43215

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST
(Specify one by circling)

Test Rate. 10 G.P.M. Duration of test 1 hrs

Drawdown 20 ft. Date 5-12-73

Static level-depth to water 15 ft.

Quality (clear, cloudy, taste, odor) Clear

Pump installed by.

WELL LOG*

SKETCH SHOWING LOCATION

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.

N.

• WELL

E.

5-17-73

M. E. Thompson

*If additional space is needed to complete well log, use next consecutive numbered form.