

WF' LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
65 S. Front St., Rm. 815 Phone (614) 469-2646
Columbus, Ohio 43215

435281

County Fayette Township Marion Section of Township _____
Owner Russell S. Ebert Address New Holland, D 43145
Location of property 2 mi. out of New Holland on Southeast
1988 Good Hope - New Holland Rd.

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST
(Specify one by circling)


Casing diameter 5 5/8 Length of casing 60' Test Rate 4 G.P.M. Duration of test 2 hrs
Type of screen — Length of screen — Drawdown 215 ft. Date 10-14-74
Type of pump Subm. Static level-depth to water 30 ft.
Capacity of pump 4 Quality (clear, cloudy, taste, odor) Clear
Depth of pump setting 221'
Date of completion 11-8-74 Pump installed by R.C.

WELL LOG*

SKETCH SHOWING LOCATION

Formations Sandstone, shale, limestone, gravel and clay	From	To
<u>Sandy Gray Clay</u>	<u>0 Feet</u>	<u>60 Ft.</u>
<u>Limestone</u>	<u>60</u>	<u>245</u>

Locate in reference to numbered
State Highways, St. Intersections, County roads, etc.



Drilling Firm Cannerwell-Drilling Date 3-10-75
Address Wilmington, D Signed Robert Canner

*If additional space is needed to complete well log, use next consecutive numbered form.

(37)